

SCCCD, Reedley College  
Meeting Minutes Schematic Design Meeting No 1  
October 27, 2017

Location:- Math Tutorial Center

Darden Project No: 1720

# LISTING OF PARTICIPANTS

## *ARCHITECTS*

Bob Petithomme Principal In-Charge  
Ramon Torres Architect

[bobp@dardenarchitects.com](mailto:bobp@dardenarchitects.com)  
[ramont@dardenarchitects.com](mailto:ramont@dardenarchitects.com)

559.448.8051  
559.448.8051

## **Attendees:**

District Administration:

Matt Kennedy

Shannon Robertson

George Cummings

See attached Sign – In sheet

## **Dental, Nursing & Science 2:00 pm October 27, 2017**

### **Overview:**

- **Bob opened the Meeting with an overview of the funding for the project that the District has provided and where the Budget funds have been allocated to date. The Budget is**
- **\$20 million and includes soft costs. Option 1 and Option 2 were presented. The Faculty prefers the Design direction that Option 2 is showing with comments noted;**
- **The Dental Faculty prefers the direction that Option 1 shows for their space of the 2 options presented.**
- **Need to add Dental Lab space. 20 seats, this is prior to students moving on to the Dental Lab Chairs**
- **Sterilization Room needs to be closer to the Dental Lab Chairs**
- **A Biology Lab with a Prep Room was requested to be added to the second Floor in lieu of one of the 3 Lecture rooms, District Administration is to determine if additional program space is to be added to the program.**

- **Concern was raised on the size of the Prep Room Shown on the second Floor and if it can store all of the current instruments they have. Building 35 has all of the instruments that need to be moved to the second floor Prep Room This will need to be verified.**
- **Chemistry Organic Lab needs 12 fume hoods and can be 48" rather than the 60" currently shown. 12 hoods with 2 students per hood only allows 24 students to work at the same time.**
- **Chemistry General Lab needs to have 4 Fume Hoods.**
- **Need 16 Hot Plates to operate at the same time.**
- **Concern was raised about students having easy access to the sink at their work stations.**
- **Staff was leaning to the open Corridor concept over the enclosed Corridor Concept.**
- **Chemistry Faculty asked if the Building was going to be provided with an emergency back - up generator, no back – up generator is planned for the building.**
- **Need to provide Office Space for Marie as well as an Assistant Office Space, within this Building.**
- **Show the Existing Green House on the Site Plan**

~~~*END OF MEETING*~~~

---